

NORTHERN PACIFIC RAILWAY COMPANY
AUTHORITY FOR EXPENDITURE

Year: 1923

Superintendent's No. 131
 No.

Dept. No. Engineering Dept. No. 102 4

A. F. E. No. 53

Saint Paul Div. Main Line District State Minn. Val. Sec. No. 9

AUTHORITY IS REQUESTED FOR A NET EXPENDITURE OF \$204.00

Accounting distribution as follows: (Distribution to be made in General Office.)

	Operating Expenses	Profit and Loss	Net Operating Expenses	Net Profit and Loss
Cost of property retired	\$	\$	\$	\$
Value of salvage				
Incidental costs				
Total to Operating Expenses				\$ 11
Total to Profit and Loss				
To Material and Supplies				
To Bills for Collection				
To Other Accounts				
Net charge to investment account—Additions and Betterments				193
Total of distribution				\$ 204

DEPRECIATION
 ELEMENT 15100

Budget reference: Not in Budget

Class of Work: No. 21

Joint facility contract reference: Not Joint

The location is - - - on this company's property. To secure rights, it will be necessary - Nothing.

Location: Northtown, Minnesota.

Title Placing Deane Duplex Steam Pump for pumping drinking water in and power room at roundhouse.

Reason: The present drinking water pump at the roundhouse has been in service since the plant was opened, and is used continuously during the twenty-four hour period each day and when necessary to shut the pump down for inspection or repairs, we are entirely out of drinking water for all employes at the roundhouse, car shop and in the yard.

As this pumping plant gets older these shut downs for inspection and repairs must of necessity become more often and to eliminate the unsatisfactory conditions and complaints from employes while plant is shut down, it is proposed to install the 6x4x8 Deane Duplex Horizontal Steam pump now located in the old General Office at St. Paul and not in use, in the power house at Northtown to use when necessary to shut down the present pump.

It is recommended the work be done during the winter months.

all A.F.E. 54-1923

Work to be done by company force under charge of Superintendent.

Checked and Entered
 President's Office

Accounting to concentrate in the office of Superintendent.


Signature and Title: Superintendent. Date December 13, 1922.

APPROVED: <i>Charles D. Brown</i> General Superintendent.	<i>W. H. ...</i> Asst. Genl. Mgr. of Engr. Maint. of Way.	<i>W. H. ...</i> Assistant General Manager.
<i>W. H. ...</i> Mech. Supt., Supt. Telf. or Signal Dept.	<i>W. H. ...</i> Chief Engineer.	<i>W. H. ...</i> General Manager.
<i>W. H. ...</i> Genl. Supt. for Comptroller.	<i>W. H. ...</i> President.	<i>W. H. ...</i> Vice President.
		Date of Final Approval } 1 25 23 } 19

COMPTROLLER'S RECORD OF NOTICE OF APPROVAL AND OF COMPLETION

Form No. 1345 issued JAN 29 1923 Work begun 19 Work finished Feb. 26, 1923

Prop Deane Duplex G 14 1/2" Serial 02882



Note - Pump moved from Old Genl Office Power Hq.

N.P.R.
 St. Paul Div - Main Line
 Propo Duplex Pump in Power Hq. @
 Northtown, Minn.
 Scale 1" = 100'
 Office Dist Engr St Paul Nov 9, 1922
 Propo work shown & d
 Yibration Sec No 9 Minn